New York State Department of Environmental Conservation

Division of Environmental Remediation, Region 9

270 Michigan Avenue, Buffalo, New York, 14203-2915 **Phone:** (716) 851-7220 • **FAX:** (716) 851-7226

Website: www.dec.ny.gov



November 18, 2009

Ms. Michelle Rhodes, PMP LOOW/NFSS Program Manager Department of the Army Buffalo District, Corps of Engineers 1776 Niagara Street Buffalo, New York 14207-3199

Dear Ms. Rhodes:

Spill Number 0806523 Lake Ontario Ordnance Works Lewiston, Niagara County

We have reviewed the UST Removal Action Closure Report dated May 29, 2009 by EEC for the above-referenced site. The confirmatory analytical sample results exceed our soil guidance values; therefore, further work is required. We require this additional work for the following areas:

- 1) Tank 2.4 West
 - 2) Tank 2.6 North and East

All other results are acceptable for the Department to issue a "no further work – inactive" status.

Please submit a work plan to address the above-listed areas by December 31, 2009.

Your cooperation is appreciated. If you have any questions, please call me at (716) 851-7220.

Sincerely,

Salvatore A. Calandra Environmental Engineer I

SAC:sz

cc: Mr. James Strickland - NYSDEC, Division of Solid & Hazardous Materials

Mr. Kent Johnson - NYSDEC, Albany

Mr. Paul Dicky - Niagara County Health Department

Mr. Jeffrey Hall - Department of the Army, Corps of Engineers